



C-13



FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2025/NDZ/ 181

Dated: 09/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Mangalore Masala (A Unit of JSR Hospitality) located at Infinity S. K. Mall Hall No. 04, Second Floor, Karkardooma Metro Station, Delhi 110092 in a building comprising of Ground plus two upper floors but Eating House is running on second floor only, owned/occupied by Mangalore Masala (A Unit of JSR Hospitality) have complied fire prevention and fire safety requirements in accordance with rule of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on dated 05/05/2025 in the presence of Mr. Anish Sharma (Manager) and that the building/premises is fit for occupancy class "Assembly" (Eating House) with effect from 09/05/2025 and up to valid 31/03/2028 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....09/05/2025.....at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

To,
The Addl. Commissioner of Police (Lic.) at 1st floor Police Station Defence Colony, New Delhi.
MCD ID No. 2025041106176

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. Construction of lift lobby or installation of Fire curtain in the lift shall be provided by the management within six months failing which Fire Safety Certificate should be treated null & void.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : **M/s Mangalore Masala (A unit of JSR Hospitality)**
Infinity S.K. Mall Hall No. 4, Second Floor Karkardooma Metro Station, Delhi-92

2. Building is comprised of : Ground plus two upper floors only
 (Restaurant is running second floor only)
 3. Type of Occupancy : Assembly Building
 4. Type of Case : New case
 5. Details of Previous NOC letter : Nil
 6. Fire Safety directive letter No. : N/A
 7. Date of Inspection : 05/05/2025
 8. Name of the Inspecting officers : DO A.K. Jaiswal & ADO Deepak Kumar
 9. Name and designation of Officer from the building side : Mr. Anish Sharma (Manager)
 10. Year of Construction : 2024
 11. Applicant's letter No : MCD ID No. 2025041106176 dated 12/04/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	7.50 mtr.	09mtr.	MR
	• Gate width	4.50 mtr.	06 mtr.	MR
	• Width of internal road	06 mtr.	06 mtr.	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	10 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr	02 mtr& 1.50 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	05 nos.	MR
	e. Width of Corridor	02 mtr	Provided	MR
	f. Door Size	1.50 mtr x02	02 mtr& 1.50 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	02 hrs	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	Provided	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	12 A/C Per hours	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	06 nos.	Provided	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI marked	Provided	MR

12 A

Common with Metro Station				
06	First-Aid-Hose Reels.			
	Total numbers on each Branch	01 nos	Provided	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
Common with Metro Station				
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	Heat & Smoke	N/A
	• Location of main panel	N/A	Provided	N/A
	• Location of repeater panel	N/A	Provided	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooter	N/A	Provided	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
Common with Metro Station				
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
Common with Metro Station				
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per Branch	01 nos.	Provided	MR
	• Hose box	01 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	06 nos.	N/A
	• Hose box	N/A	06 nos.	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Metro Station		
	• Discharge of main pump	N/A	2850 lpm	N/A
	• Head of main pump	N/A	60 M	N/A
	• Number of main pumps	N/A	01nos	N/A
	• Jockey pump out put	N/A	180 LPM	N/A
	• Jockey pump head	N/A	70 M	N/A
	• Standby pump out put	N/A	2850 lpm	N/A
	• Standby pump head	N/A	60 M	N/A
	• Auto starting /manual stopping	N/A	Provided	N/A
	• Pump house access	N/A	Provided	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Imp	450 Imp	MR
	• Head of the pump	60 M	60 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
Common with Metro Station				
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 ltr	1,00,000 ltr + 1,00,000 ltr	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	Required	Provided	MR
	• Pressurization of lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	Provided	N/A
	• Flow switch panel	N/A	Provided	N/A
	• PA system panel	N/A	Provided	N/A
	• Battery backup	N/A	Provided	N/A
	• Building floor plans	N/A	Provided	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	Required	Provided	MR

Note: Infinity S. K. Mall Karkardooma Metro Station FSC has already been vide letter No. F.6/DFS/MS/Metro/2025/NDZ/169 dated 07/04/2025. ^{issued *}

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- A.D.O (Shd)

Signature of the Inspecting Officer
 Name :- A.K. Jaiswal
 Designation :- D.O (ED)

Dy CTO / (NDZ)

Diry
06/05/25

C.F.O.

7/5/2025

Director
AS/MS

AND/STP

4/2025 online pr
 [Signature]