

C/52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2025/265

Dated 02/06/2025

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in.

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s. Mannat International,
located at 9336 to 9345, Multani Dhanda, Paharganj, New Delhi-110055.

Sir,


Please refer to your Online Application ID. No. 2025042807380 dated 06/05/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 19/05/2025 in the presence of Sh. Deepak Nagpal to check the Fire safety arrangements.

During inspection, it was observed that the guest house is running at ground + 03 upper floors, in a building comprised of ground + 04 upper floors, ground floor (reception + 02 guest rooms), 1st floor to 3rd floor (08 guest rooms at each floors), (total 26 guest rooms), 4th floor (owner's residence). Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, MOEFA, Pumping Arrangement & Exit Signage etc, are provided. However, following shortcomings were observed:-


1. First aid hose reels are provided but not functional.
2. MOEFA is provided but not functional.
3. 450 LPM pump is provided but not functional.
4. Overhead water storage tank of 3,000 ltrs is provided against requirement of 5,000 ltrs.

In view of above shortcomings, the application for issuance fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


VIRENDRA SINGH
CEO
(Atul Garg)

 Director


23/5
21/5/2025

Copy to: -

1. The Dy. Health Officer, Karol Bagh Zone, Anand Parbat, New Delhi.
2. The Owner/Occupier, Mannat International, located at 9336 to 9345, Multani Dhanda, Paharganj, New Delhi-110055. Online Application ID. No. 2025042807380 dated 06/05/2025