

c/68



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/School/2025/ 415

Dated: 20/05/2025

To

The Principal,
 Manvi Public School,
 Block-C-7, Sector- 07, Rohini,
 Delhi-110085.

Subject: Renewal of fire safety certificate Manvi Public School, Block-C-7, Sector- 07, Rohini, Delhi-110085.

Sir,

Kindly refer to online e-mail dated 14.03.2025, received in this department on the subject cited above. In this connection it is to inform you that the building premises has been visited by the officers concerned of this department on 06.05.2025 presence of **Mr. Kishan Mishra** and observed that the shortcoming already issued by this department letter of even no. 492 dated 02.08.2024 are not yet rectified and during the inspection, some shortcomings has been found. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Shortcoming already conveyed are not yet rectified.
2. Parking area of school in basement found converted into class rooms.
3. Auto start pump not provided.
4. Exhaust fan in basement ventilation found removed & natural ventilation on upper floors found blocked.

In this regard as stipulated in sub Rule 35 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "I" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours Faithfully

(Atul Garg)
 DIRECTOR

Ph; 011-23414000

Copy to:

1. The Director of Education, Old Secretariat, Delhi-110054.