



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001





No. F6/DFS/MS/School/WZ/2025/ 980

Dated: 11/08/2025

FIRE SAFETY CERTIFICATE

Certified that **Manvi Public School, Block- C-7, Sector-7, Rohini, Delhi 110085** comprised of basement + ground + two upper floors and **school is running at Ground + 02 upper floors**, basement use for storage purpose only given by undertaking by school management owned / occupied by **Manvi Public School** was issued fire safety certificate by this department vide letter no **F6/DFS/MS/School/WZ/2021/444 dated 07.07.2021**. The premises was re-inspected by the officer concerned of this department on **27.07.2025** in the presence of **Mr. Mukesh Jindal (Accountant)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements rule 33 of the Delhi Fire Service Rules, 2010, and premise is fit for class "B Educational Buildings" with effect from 11/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 11/08/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer


Copy to:

1. The Principal, Manvi Public School, Block-C-7, Sector- 07, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi-110054

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Ru](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)
[les/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

INSPECTION REPORT

1. Name & address of the building : Manvi Public School, Block C-7, Sector -07, Rohini, Delhi -85
2. Type of Occupancy : Education
3. Comprised of building : Basement + Ground + 02 upper floors
4. Type of Case : Renewal –Ground + 02 upper floor (basement use for storage purpose only)
5. Details of Previous NOC : F.6/DFS/MS/School/WZ/2021/444 dated 07.07.2021
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 27.07.2025
8. Name of Inspecting Officer : A. K. Sharma ADO (Rohini)
9. Name and designation of officers
From the building side : Mr. Mukesh Jindal (Accountant)
10. Year of Construction : OD No.3008 dated 23.06.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none">Road width	Accessible	Accessible	MR
	<ul style="list-style-type: none">Gate width	4.5m	Accessible	MR
	<ul style="list-style-type: none">Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none">Upper Floors	02nos.	02nos.	MR
	<ul style="list-style-type: none">Basements	02nos.	03nos.	MR
	b. Width of staircases			
	<ul style="list-style-type: none">Upper Floor	1.50 m	1.50 m & 1.24 m	MR (old case)
	<ul style="list-style-type: none">Basements	1.50 m	1.50 m 1.10 x 02	MR (old case)
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none">Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	01nos.	01nos.	MR
	f. Door Size	-NA-	-NA-	-NA-
		1 m	1 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none">Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none">Sealing of electrical shafts	-NA-	-NA-	-NA-
	<ul style="list-style-type: none">Fire Rating of shaft door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none">Water Curtain	-NA-	-NA-	-NA-
	<ul style="list-style-type: none">Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none">Basements	30 a/c per hour	Exhaust fan	MR
	<ul style="list-style-type: none">Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none">Total numbers	08 No's ABC/CO2 ISI Marked	10 No's	MR
	<ul style="list-style-type: none">Types		ABC 10	MR
	<ul style="list-style-type: none">IS marking		Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none">Total numbers on each floor	01nos. 30 m	Provided	MR
	<ul style="list-style-type: none">Length of hose reel hose		30 m	MR


	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel		-NA-	-NA-
	• Location of Repeater Panel		-NA-	-NA-
	• Alternate source of power		-NA-	-NA-
	• Hooters' Location		-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-

MR


	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 415 dated 20.05.2025, the FSC issued vide letter no. F6/DFS/MS/School/WZ/2021/444 dated 07.07.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name: Ajay Kumar Sharma
 Designation ADO/Rohini

DO (NW)


 30/07/2025
 Dy CPO (WZ)


 30/7

DCFO/201/NW...

Dated 30/07/25...

CFO/

 4/8/2025
 Principal Director

CFO to Sme.

 04/08/25

ADO (Rohini)


CFO/


Fr letter is put up for ICD personal and signature please.

CFO/

 4/8/2025
 M S cell


 16/8/25