

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2026/WZ/ 745

Dated: 30/07/2026

To,

The Owner/Occupier,
Mardigras by Uncover (A unit of KIKI foods LLP),
Plot No. 31, Sec. 09, Dwarka, New Delhi- 110075.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s. Mardigras by Uncover (A unit of KIKI foods LLP) Plot No. 31, Sec. 09, Dwarka, New Delhi- 110077.


Sir,

This has a reference to MCD online application ID No. 2026062609319 dated 29.06.2026, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the eating house/ restaurant building on dated 18.07.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Manager was present and it was observed that the building is comprised of basement (other's property), ground and first floor (restaurant), second floor (office) and following shortcomings were observed: -

1. Terrace level pump of 900 LPM provided but not functional in auto mode.

Keeping in view of the above, issuance of fire safety certificate can-not be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department, and running eating house/ restaurant in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully



(S.K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi, w.r.t. MCD Portal ID -. 2026062609319 dated 29.06.2026.