



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

261  
75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/SZ/2025/ 34

Dated: 03/03/2025

To

The Joint Commissioner of Police,  
Office of Joint Commissioner of Police: Licensing,  
1<sup>st</sup> Floor, P. S Defence Colony, New Delhi.

**Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Marina Dreams Banquet Hall (A Unit of Chintpurni Overseas Private Limited) located at B-72/5, Wazirpur Industrial Area, New Delhi-52.**

Sir,

With reference to the etl.mcdonline application ID no. 2025020801628 on the subject cited above, it is informed that the said Banquet hall was inspected officer concerned from this department on 21.02.2025 in the presence of Mr. Sanjay Goel (Owner) and it was observed that the Banquet hall running at Ground + 2 upper floor in a building comprised of Basement + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire Check Door (FCD) found removed at many places.
2. Ventilation system in basement is inadequate and non functional.
3. Kitchen from the assembly area at First floor must be removed.
4. Location of main exit doors at First floor are not matching the approved plan.
5. All water based systems like Hose reels, Internal Hydrants, Sprinklers, Fire Pumps are non functional.
6. Manual Operated Electrical Fire Alarm (MOEFA) system and Automatic Fire Detection and Alarming System (ADAS) found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

**Copy to:-**

1. The Commissioner, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi.

27/2/2025