

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2025/SZ/ 15
To

Dated: 07/01/2025

The Principal,
St. Mary's School,
Madan Sara Mathew Lane,
B-2, Block, Safdarjung, Enclave,
New Delhi 110029

Sub: Regarding renewal of FSC in r/o **St. Mary's School**, located at Madan Sara Mathew Lane, B-2, Block, Safdarjung, Enclave, New Delhi 110029.

Sir,

This has reference to letter received through outdoor dairy not 10185 dated 10/12/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.12.2024 in the presence of Mr. Vargees (Admin) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found non-functional.
2. Automatic sprinkler system provided but found non-functional.
3. Internal hydrant provided but found non-functional.
4. Terrace level Fire Pump capacity of 900 LPM provided but found non-functional.
5. Overhead tank capacity 20,000 ltrs provided but it is being use for domestic/other purposes. The fire fighting shall be dedicated for firefighting purpose only.
6. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 54