



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आपदादीन
अमृत महोत्सव


No. F6/DFS/MS/EH/NDZ/2025/219

Dated: 03/06/2025

FIRE SAFETY CERTIFICATE (FSC)

Certified that the M/s Massala Singh (A Unit of Auram Foods Pvt. Ltd.) earlier Restaurant operating by the name M/s Biryani Badshah located at K-14, Outer Circle, Connaught Place, New Delhi, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2019/1645 dated 20.08.2019 for ground floor only. The building was re-inspected by officer concerned of this department on 28.05.2025 in the presence of Mr. Gyan Jaiswal (Manager) and found that the Restaurant is running on Ground + Mezzanine floor of the building comprised of Ground (with mezzanine) + 02 upper floors. The Restaurant has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building is fit for occupancy of Group D "Assembly Building" (Restaurant) with effect from 03/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 03/06/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
29/5 29/5

Reference: etl.mcdonline application no. 2025052108849.

Copt to:

1. The Chairman, NDMC; Palika Kendra New Delhi-110001.

Conditions for the validity of Fire Safety Certificate

1. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT				
1	Name & address of the building	M/s Massala Singh (A Unit of Auram Foods Pvt. Ltd.) located at K-14, Outer Circle, Connaught Place, New Delhi.		
2	Building is comprised of	Ground (with a small mezzanine portion) + 02 upper floors Restaurant running at Ground + Mezzanine floor of the building		
3	Type of occupancy	Group-D, Assembly Building, (Restaurant).		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/EH/NDZ/2019/1645 dated 20.08.2019		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	28.05.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Gyan Jaiswal (Manager)		
10	Year of construction	Old Heritage		
11	Applicant's letter no.	etl.mcdonline application no. 2025052108849		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per Rules 35 (6)	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
A	Road width	9.0 mtrs	16.0 mtrs	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases	Required	2 nos.	MR
a	Upper floor/Mezzanine	NA	NA	NA
b	Basement	NA	NA	NA
B	Width of staircases	02 exits	0.90 m (only 1 step) to 1.40 m & 1.50 m	MR (old case)
a	Upper floor/ Mezzanine	NA	NA	NA
b	Basement	NA	NA	NA
C	Protection of exits	NA	NA	NA
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	NA	NA	NA
F	Door size (exits)	02 exits	1.70 m & 0.66 m to 0.90 m	MR (old case)
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	Mechanical/ Natural	Natural	MR
5.	Fire Extinguisher:			
A	Total numbers	10 nos.	13 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reels:			
A	Total numbers of each floor	01no.	01no.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection And Alarming System:			
A	Type of detectors	Required	Smoke	MR
B	Location of main panel	Required	Provided	MR
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	Provided	NA
8	MOEFA:	Required	Provided	MR
9	Public Address System:	NA	NA	NA
10	Automatic Sprinkler System:			
A	Basement	NA	NA	NA
B	Ground floor/Mezzanine	Required	Provided	MR
C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box at each floor	01 no.	01 no.	MR
12	Yard Hydrants:			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements:			
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
i)	Pump house access	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	450 + 280 LPM	450 + 280 LPM	MR
b)	Head of the pump	30 mtrs.	Provided	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage For Fire Fighting:			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	10,000 ltrs	15,000 ltrs	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA

N/27.

M/s Massala Singh located at K-14, Outer Circle, Connaught Place, New Delhi

19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide but Not Functional (PNF).

Note:- The last Fire Safety Certificate (FSC) had been issued to M/s Biryani Badshah located at this address (K-14, Outer Circle, Connaught Place, New Delhi) but now another Restaurant operating by the name 'Massala Singh' (A Unit of Auram Foods Pvt. Ltd.) at the same address. The initial proposals at N/1, N/2 and N/3 indicate that FSC had been recommended and issued for Restaurant at Ground + Mezzanine floor with two exits at each floor irrespective of width. There is no change in occupancy since the issuance of 1st FSC, hence old parameters may be accepted.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2019/1645 dated 20.08.2019 is recommended to be renewed with a different name (i.e. Massala Singh) under Rule 37 of the Delhi Fire Service Rules 2010.

[Signature]
29/8/25
Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (CD)

[Signature]
29/8/25

[Signature]
29/8/25

[Signature]
26/8/25

[Signature]
26/8/25

[Signature]
26/8/25

[Signature]
26/8/25

[Signature]
05/8/25

[Signature]