

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No.F.6/DFS/MS/School/2025/SZ/1045

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mata Gujri Public School**, at Gurdwara Singh Sabha (opp. C Block), Greater Kailash -I, New Delhi-110048 comprised of 03 Blocks, Block 01- G+3, Block 02- G+1, Block 03- B+G+2 upper floors owned/occupied by Mata Gujri Public School, was issued Fire Safety Certificate by this department vide letter no. F6/MS/DFS/School/2022/SZ/821 Dated 29-07-2022. The premises was re-inspected by officer concerned by this department on 04/08/2025 in the presence of Mrs. Daljeet Kaur Bhandari of the school and observed that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no 262-362 dated 17/01/2005 and that the building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from 21/08/2025 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 21/08/2025 at New Delhi by


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Mata Gujri Public School, Gurdwara Singh Sabha (opp. C Block, Greater Kailash -I, New Delhi-110048
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Mata Gujri Public School, Gurdwara Singh Sabha (opp. C Block, Greater Kailash -I, New Delhi-110048)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Three Blocks :-1 st Block- Ground + Three Upper floor, 2 nd Block- Ground plus First floor, 3 rd Block- Basement, Ground + 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2022/SZ/821 Dated 29-07-2022		
6	Fire Safety Directives Letter No	DOE circular no 262 to 362 dated 17/01/2005		
7	Date of Inspection	04-08-2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Daljeet Kaur Bhandari		
10	Year of construction	2007		
11	Applicant letter No.	Outdoor diary no 4058 dated 23-07-2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Accessible	06 mtr	MR
	• Gate width	NA	4.5 mtr	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No's	Blk-1- Ground to terrace 02 No, ground to 2 nd -01 ground to 3 rd -01 no Blk-2-02 No's Blk -3-02 No's	MR
	➤ Basement floor.	02 No's	02 no's	MR
	b) Width of Staircase			
	➤ Upper floors	1.50m/0.75m	Blk-1- Ground to terrace- 1.30 & 1.1.m ground to 2 nd -3.40m, ground to 3 rd -1.39m Blk-2-1.40m each Blk -3-1.50 m each	MR (old Case)
	➤ Basement floor	1.50m/0.75m	1.45m & 1.2o m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Blk- 02 No Blk- 01 No Blk- 01 No	Blk- 02 No Blk- 01 No Blk- 01 No	MR MR MR
	e) Width of corridor	1.50 m	Provided	MR
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	36 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 No's at each	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection & alarming system.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	2 x 450 LPM	2 x 450 LPM	MR
		40m each	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	Exit Signage.	15,000 Ltrs	15,000 Ltrs	MR
16.	Provision of Lifts.	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/17

Special Fire Protection System for the Protection of special Risk, if any.

-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2022/SZ/821 Dated 29-07-2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Signature]
06/08/2025

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

[Signature]
13/8/25

CFO/
[Signature]
18/8/2025

Principal Director

CFO to *[Signature]*

CFO

[Signature]
19/8/25

[Signature]
20/8/2025

ADO (BCP)

F.T. letter is put up for your signature

21

[Signature]
21/8/2025

CFO/HQ
[Signature]
21/8/2025

MS