



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/1358

Dated: 27/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Mata Jai Kaur Public School located at Ashok Vihar Phase-III, Delhi-52, comprised of Basement, Ground + 02 upper floors owned/occupied by Mata Jai Kaur Public School was granted FSC by this department vide letter No F.6/DFS/MS/School/WZ/2022/1218 dated 07.11.2022. The premises was re-inspected by the officer concerned of this department on 14.11.2025 in the presence of Mr. Amandeep Singh and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 27/11/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 27/11/2025 at New Delhi

(S. K. Dua)
 26/11/25

Dy. Chief Fire Officer (WZ)
 Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Mata Jai Kaur Public School located at Ashok Vihar Phase-III, Delhi-52.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Mata Jai Kaur Public School, located at Ashok Vihar Phase-III, Delhi-52.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Basement, Ground Plus Two Upper Floors)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2022/1218 dated 07.11.2022			
5. Fire Safety directives letter No	D.O.E Circular 3298-3398 dated 01.03.2011			
6. Date of inspection	14.11.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)			
8. Name and designation of officers From the building side	Mr. Amandeep Singh			
9. Year of Construction	1973-77			
10. Applicant's letter No.	Outer Diary No-6724 dated 06.10.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6) of DFS Act/ DOE. Cir. dated 01.03.2011.	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	Accessible	2.50m	MR being Old case
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	5 + 01 ramp	Provided	MR
	• Basements	02nos.	Provided	MR
	b. Width of staircases			
	• Upper Floor	1.5m	1.48m, 1.40m, 1.30m, 1.15m & Ramp-1.40m, G to FF-1.30m	MR Being old case
	• Basements	1.5m, 1m	1.20m & 1.10m	MR Being old case
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	Provided	MR
	e. Width of Corridor	1.5m	2.35m	MR
	f. Door Size	1m	1.05m	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	30 a/c per hour	Exhaust fan provided	MR
	b) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	a) Total numbers	30nos.	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	03nos.	Provided	MR

N-22

	b) Length of hose reel hose	30nos.	Provided	MR
	c) Nozzle diameter	5nos	Provided	MR
7.	Automatic fire detection and alarming system			-NA-
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			MR
	a) Basement	Required	Provided	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants-All the three down comers connected with separate pumps of 450lpm and 01 pump of 450lpm for basement			
	a) Size of riser/down-comer	100m	Provided	MR
	b) Number of hydrants per floor	03nos.	Provided	MR
	c) Hose Box	03nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	15,000lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-

	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2022/1218 dated 07.11.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Ajaye
18/11/25
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Wazirpur/MN)

DO (W)

11
19/11

24/11/25

Principal Director

21/11/25

21/11/25

21/11/25

F.T. please.

ADO (WZ)

Fr letter is sent up for kind perusal and signature please.

24/11/25

21/11/25

DO (WZ)

F.P. wing