

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2025/SZ/ 1009

Dated: 18/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mata Kasturi Devi Sr. Sec. Public School** located at Gopal Nagar, Najafgarh, New Delhi-110043, comprised of ground floor plus two upper floors, owned/occupied by Mata Kasturi Devi Sr. Sec. Public School, was issued FSC vide letter No. F.6/DFS/MS/School/2016/SZ/992 dated 09/06/2016. The School Building was re-inspected by the officer concerned of this department on 28.07.23025 in the presence of Sh. Kulbhushan Singh (Manager) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus two upper floors) is fit for occupancy class "Educational Building" w.e.f. 18/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 18/08/2025 at New Delhi by.


 (Virendra Singh)
 Chief Fire Officer
 Delhi Fire Service
 Jey.

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Mata Kasturi Devi Sr. Sec. Public School located at Gopal Nagar, Najafgarh, New Delhi-110043.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Mata Kasturi Devi Sr. Sec. Public School, Gopal Nagar, Najafgarh, New Delhi-110043.
2. Building is comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2016/SZ/992 dated 09/06/2016
6. Fire Safety directives letter No : N/A
7. Date of inspection : 28.07.2025
8. Name of Inspecting Officer : A.D.O. R.K Yadav
9. Name and designation of officers
From the building side : Sh. Kulbhushan Singh
10. Year of Construction : 1989-90 (as per recognition letter of Director of Education Delhi for 1st to 5th class) (placed at C-33)
11. Applicant's letter No. : Nil dated 01.07.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 m) 4.5 m N/A	Provided 5.9. 3.95 & 1.7 m N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No's N/A	02 No. N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m & 0.75 m N/A	1.60 m & 1.0 m N/A	MR, old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	02 to 3.3 m	MR
	f. Door Size	1.0 m	0.90/1.0 m	M/R, old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	07 no's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR

N/23

18.

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	N/A	N/A	N/A
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping <ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	(No Lift)		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

N/24

18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/School/2024/SZ/601 dated 06.09.2024 have been rectified.

Note: - As per undertaking submitted by Manager of the school (placed at C-34) that the school building was constructed in the year 1989-90 and the school is running in the building since then and was recognized up to class 8th as per DoE letter dt. 12.06.1990 (placed at C-33), up to class 10th as per DoE letter dt. 23.04.1991 (placed at C-30) and up to 12th class as per DoE letter dt. 15.04.1996 (placed at C-27).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2016/SZ/992 dated 09/06/2016, renewal under rule 37, of the Delhi Fire Service Rules, 2010, is recommended.

R.K. Yadav
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

R.K. Yadav
5/8/25

CFO
8/8/2025

Principal Director

CFO to DoE.

CFO

11/8/25
12/8/2025

ADO/JKP

PRD