

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 30

Dated: | 5/0 | /2025

To

The Principal Mata Ramrakhi Sanatan Dharam Saraswati Bal Mandir, C-67, Mahendru Enclave, Delhi-110033.

Sub: - Regarding renewal of fire safety certificate in r/o Mata Ramrakhi Sanatan Dharam Saraswati Bal Mandir located at C-67, Mahendru Enclave, Delhi-110033.

Please refer to your letter received through online e-mail dated 25.12.2024 on the subject Sir. cited above. In this connection this is to inform you that the above mention site was visited by the officer concerned of this department on 03.01.2025 in the presence of Smt. Priyam Singh (Accountant) was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the education building is comprised of Ground & 02 upper floors each. The observations/ shortcomings made are as under:-

Fire Extinguisher is provided but not functional.

2. Hose reel hose is provided but not functional and shut off nozzle found missing.

3. Terrace level fire fighting pumps capacity of 450lpm is provided but not functional.

Terrace level fire water tank is provided but empty.

5. Exit & floor signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

Pb.-011-23414000

Copy to:-

1. The Dy. Director of Education, GNCT of Delhi, Zone-IX, District North West-A, Shalimar Bagh, BL- Block, Delhi- 110088.