

c/35



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2025/WZ/ 377

Dated: 13/05/2025

To,

The Principal,
Mata Shiv Devi Public School,
A-2, Keshavpuram, Delhi- 110035.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Mata Shiv Devi Public School located at A-2, Keshavpuram, Delhi- 110035.

Sir,

This has reference to your letter no. MSD/PC/2025/320 dated 15/04/2025 received through outdoor diary no. 644 dated 16/04/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 01.05.2025 to see the functionability of the requisite fire safety measures. Sh. Saurabh Sharma was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Ground and Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Smoke management system in basement found removed.
2. First aid hose reels found damaged.
3. Internal hydrants found provided but not functional.
4. Terrace level pump found provided but not functional.
5. Overhead tank found empty.
6. Exit signage's found removed at some places.
7. Form J & K is not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

See A
2158

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.