

C 27

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/*college*/43

Dated:- .05/05/2025

To,

Ms. Prof. Harpreet Kaur (Principal),
Mata Sundri College for Women,
University of Delhi, Mata Sundri Lane,
New Delhi-110002.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Mata Sundri College for Women,
University of Delhi, Mata Sundri Lane, New Delhi-110002.**

Sir,

This has reference to your letter no. MSC/ADMN/325/2024-25/2213 dated 20.03.2025, on the subject cited above. In this regard, it is to inform you that the matter was examined and observed that this department has already issued shortcomings vide letter no **F6/DFS/MS/2017/475** dated 27.12.2017 (copy enclosed) in response to your application dated 24.11.2017 regarding approval /regularization of building plan from fire safety point of view ,which is not complied so far.

In view of above, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the point wise compliance of aforesaid letter for further consideration in the matter.

Encl: As above.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

1/5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F. 6 / DFS / MS / 2017 / 475

Dated 27.12.2017

To

The Principal,
Mata Sundri College for Women,
Mata Sundri Lane,
Delhi - 110002.

Sub: - Regarding regularization/ approval from fire safety point of view of Mata Sundri College for women building at Mata Sundri Road, New Delhi.

Sir,

Please refer to your letter no. MSC/ADMN/3251/2017-2558 dated 24.11.2017 received in this office on 12.12.2017 on the subject cited above. In this connection, this is to inform you that the plans submitted in respect of proposed / existing blocks at Mata Sundri College, Mata Sundri Road, New Delhi have been scrutinized from fire safety point of view and observed that two blocks namely Administrative Block comprised of ground mezzanine plus four upper floors and Auditorium Block comprised of ground, mezzanine plus two upper floors have been proposed for approval. The height of the proposed blocks is Administrative Block - 19.5 meter and Auditorium Block not mentioned. Following shortcomings have been observed in the plans:

Administrative block


1. The plans have not been forwarded through building sanctioning authority i.e North Delhi Municipal Corporation.
2. Fire safety arrangements as per UBBL-2016 / NBC Part-IV 2016 have not been marked on the plans.
3. Six meter road wide road for fire tender movement has not been proposed in the plans.
4. Width of staircases and doors has not been mentioned in the plans.
5. Terrace plan has not been submitted with the plans.
6. Fire control room has not been proposed on the plans.
7. Terrace tank for fire fighting, pump & inspection ladder has not been marked on the plans.

Auditorium Block

1. The plans have not been forwarded through building sanctioning authority i.e North Delhi Municipal Corporation.
2. Sitting plan has not been submitted with the plans.
3. Fire safety arrangements as per UBBL-2016 / NBC Part-IV 2016 have not been marked on the plans.
4. Width of doors has not been mentioned in the plans.
5. Terrace plan has not been submitted with the plans.
6. Elevation and section plan has not been submitted with the plans.
7. Terrace tank for fire fighting, pump & inspection ladder has not been marked on the plans.

In view of the above, the applicant may be requested to submit the plans after rectifying the above said shortcomings for further necessary action.

Yours faithfully,


Virendra Singh)
Dy. Chief Fire Officer
T. No. 23412025

26/12/17