

C/1119

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/NDZ/2025/295

Dated: 30 /06 /2025

To
The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 02.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Match Box (A Unit of AVV Hospitality) located at Plot No. 9-A, 3rd & 4th Floor, Hauz Khas Village, New Delhi - 110016.

Sir,

This has reference to MCD online application ID No. 2025060209457 dated 02.06.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.06.2025 in presence of Mr. Sudhir and it was observed that building is comprised of ground + 04 upper floors but restaurant is running at 3rd & 4th floor. During inspection, following shortcoming was observed:

1. One number door width of 1.50 m provided against the requirement of two number width of 1.50 m each.

In view of above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service
Tel: 01123414000

o/c
8/6
20/6

Copy to:-

The Licensee,
M/s Match Box (A Unit of AVV Hospitality) at Plot No. 9-A, 3rd & 4th Floor, Hauz Khas Village,
New Delhi - 110016.