



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 162

Dated: 17/02/2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Maxfort School** located at Plot No. 9, Sector-7, Dwarka, New Delhi-110075, comprised of Basement, Ground & 4 Upper Floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/SZ/2022/385 dated 06/04/2022. The premise was re-inspected by the officer concerned of this department on dated 31/01/2025 in the presence of Sh. Jaiveer Singh (System Admn) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "**Educational Building**" with effect from 17/02/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/02/2025 at New Delhi by

(Atul Barg)
Director
Delhi Fire Service

Copy to: -

1. The Manager, Maxfort School located at Plot No. 9, Sector-7, Dwarka, New Delhi-110075
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Condition for the validity of fire safety certificate:

- 1 The stairs/ passage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 Basement shall be used strictly in accordance with BBL.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
- 7 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of DFS Rules, 2010, form is available on www.dfs.delhigovt.nic.in.

10-27

INSPECTION REPORT				
1.	Name & address of the building	Maxfort School located at Plot No. 9, Sector-7, Dwarka, New Delhi-110075		
2.	Type of Occupancy	Educational Building (Group-B)		
3.	Building Comprised of	Basement, Ground + 04 upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/SZ/2022/385 Dt. 06/04/2022		
6.	Fire Safety directives Letter No.	F6/DFS/MS/BP/2003/84 Dt. 09/01/2003 (B+G+3) F6/DFS/MS/BP/2015/03 Dt. 02/01/2015 (B+G+4)		
7.	Date of inspection	31/01/2025		
8.	Name of the Inspecting Officer	ADO (SJ/DWK)		
9.	Name and designation of Officer from the building side	Sh. Jaiveer Singh (System Admn)		
10.	Year of Construction	2006 & 2018		
11.	Applicant's letter No.	Outdoor Diary No. 11329 dated 13/01/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos	4 Nos	MR
	• Basements	4 Nos	4 Nos	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR
	• Basements	1.5 mtr	2x1.5m & 2x1.35m	MR (Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	4 Nos	Provided	MR
	e. Width of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1m & 1.20m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Managements System			
	• Basements	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 Nos/Floor	Provided	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	04 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

N-23

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	Provided (Smoke)	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Battery backup	MR
	• Hooters' Location	-NA-	Near Staircase	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 Nos	04 Nos	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	03 Nos	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	60m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	2 x 900 LPM & 1 x 180 LPM	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	75,000 Ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000 ltrs	30,000 ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	CO ₂ Fire Extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/SZ/2022/385 dated 06/04/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

Suman
10.02.25

DO (SW)

Sw
11/2/25

CS
11/2/25

Director

13/2/25

Any/SJ

Sir,

F.T. letter is put up for your sing. p

Director

Suman
14.02.25