

C-24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2025/106

Dated: 14/02/2025

To

The Principal,
Mayur Convent Public School,
Som Bazar Chowk, Shiv Vihar,
Ph.-IV, Karawal Nagar, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Mayur Convent Public School, Som Bazar Chowk, Shiv Vihar, Ph.-IV, Karawal Nagar, Delhi-110094.

Sir,

This has reference to outdoor dairy No. 11318 dated 13/01/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 07/02/2025 in the presence of Mr. Shyam Singh and observed that at present school is Ground plus one upper floor only. Fire safety measures were checked as per the rules and following shortcomings were observed.

1. No access at terrace is provided v.i.z. no staircase is terminating at terrace, hence, Over Head Tank, Fire Pump etc. could not be checked.
2. Hose reel hose provided but found non-functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-53.