



No. F6/DFS/MS/School/NDZ/2025/ 1013

Dated: 18/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mayur Public School** located at **I. P Extension, Delhi - 110092**, building comprised of Basement (Closed), Ground plus three upper floors only, owned/occupied by **Mayur Public School** was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2022/1202 dated 03/11/2022. The school building was re-inspected by the officer concerned of this department on 25/07/2025 in presence of Mr. N.S Rawat (Chairman) & Mrs. Swati Verma (HOS) and found that the said school building have deemed complied with the fire prevention and fire safety requirements provided in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **"Educational Building" (Group - B) for ground plus three upper floors only** with effect from **18 / 08 / 2025** for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/08/2025 at New Delhi by.


VIRENDRA SINGH
CHIEF FIRE OFFICER
o/c DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, Mayur Public School located at I.P Extension, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground plus three upper floors only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. At the time of inspection not in use basement.
9. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & address of the building	Mayur Public School located at I.P Extension, Delhi - 110092.		
2	Building is comprised of	Basement (Closed) + Ground + 03 upper floors + temporary terrace floor (Closed)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/1202 dated 03/11/2022		
6	Fire safety directives letter no.	N/A		
7	Date of inspection	25/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / (L.N) & Ashok Kumar Jaiswal, D.O / (ED)		
9	Name of the designation of officer from the building side	Mrs. Swati Verma (HOS) & Mr. N.S Rawat (Chairman)		
10	Year of construction	2000		
11	Applicant's letter no.	Email dated 10/07/2025		Remarks MR/NMR
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	
1	Access to Building:			
	A Road width	6.0 mtrs.	10 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			MR
	a Upper floor	02 no.	04 nos.	N/A
	b Basement	N/A	N/A	
	B Width of staircases			MR
	a Upper floor	1.5 mtrs.	1.7 mtrs. each	N/A
	b Basement	N/A	N/A	
	C Protection of exits			N/A
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	MR
	D No. of continuous staircases to terrace	02 nos	02 nos	
	E Width of corridor	1.5 mtrs.	1.5 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

5. Fire Extinguisher:				
A	Total numbers	12 nos.	12 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	02 no	02 no	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	Provided	N/A
9	Public Address System:	N/A	Provided	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	100 mm	N/A
B	Number of hydrants per floor	N/A	02 nos	N/A
C	Hose box	N/A	02 nos	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

①

②

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	10,000 liters	10,000 liters
	E	Overhead tank capacity	Required	Provided
15	Exit Signage:			
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	Required	Provided
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

Note: At the time of inspection basement (Closed) and school running on ground plus three upper floors only, temporary porta cabin on terrace floor closed (As per undertaking and photo enclosed at C/62-64).

The fire protection system provided in the school building were tested, checked a random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/NDZ/2022/1202 dated 03/11/2022, **renewal** under Rule 35 of the Delhi Fire Service rules 2010, is **recommended**.

Signature of the Inspecting Officer
Name : Yashwant Singh Meena
Designation: ADO /Laxmi Nagar

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: Divisional Office/ Eas

Dy CFO/NDZ

31/7/2025

CFO/

9/8/2025

Principal Director

CFO to Smt.

DO(ND)

18/8/2025

CFO/

13/8/2025

ADO

P.T.O