



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/SZ/2026/ 695

Dated: 17/07/2021

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Mc Donald's Family Restaurant located at 47, Basant Lok, Vasant Vihar, New Delhi-57.

Sir,

With reference to the elt.mcdonline application no. 2026061708992 on the subject cited above, it is informed that the said Eating House was inspected by officer concerned of this department on 06/07/2026 in the presence of Mr. Akhtar (Manager) and following shortcomings were observed.

1. Alternate exit in basement found sealed.
2. Fire Check Door in electrical panel room is required to be provided.
3. Hose reel at 1st floor found removed.

In view of above shortcomings, the application of renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(A. K. Malik)

Chief Fire Officer

Copy to:-

1. The Owner/Occupier/Manager, M/s Mc Donald's Family Restaurant located at 47, Basant Lok, Vasant Vihar, New Delhi-57.