

C/22



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 362

Dated: 09/05/2025

To,

The Incharge
M.C. Primary Co-ed School, F & G,
Sant Ravidas Nagar, Jahangirpuri, Delhi-09.

Sub:- Regarding issuance of fire safety certificate in r/o M.C. Primary Co-ed School (School ID No- 1253057) located at F & G, Sant Ravidas Nagar, Jahangirpur, Delhi-110033.

Sir,

Please refer to your letter no. nil dated 25/03/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 30/05/2025 to verify the fire safety arrangements provided therein as per the Director of education dated 01.03.2011. At the time of inspection Sh. Raju (Attendant) was also present at site and said building was comprised of 04 blocks interconnected, ground & first floor only. Your request for FSC is rejected under Rule 35 due to following shortcomings.

1. There is 04 nos. of staircase continues from ground to first floor only needs to all the staircases required from ground to terrace level.
2. All classroom door size is 90cm provided against the requirement of 01m.
3. Electrical panel below staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully,

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.