

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 364

Dated: 09 /05/2025

To

The Incharge, M.C. Primary Boys/Girls School, Azadpur Village, Delhi-110033.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Boys/Girls School (School ID No- 1253043/44) located at Azadpur Village, Delhi-110033.

Sir,

Please refer to your letter No.nil dated: 17/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 05/05/2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that the building was comprised of ground & 03 upper floors only. At the time of inspection Smt. Anita (Incharge) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- The school main gate width is 3.50m against the requirement of 4.50m.
- Only one staircase is provided from ground to terrace level and alternate staircase from ground to 3rd floor only both staircase required from ground to terrace level.
- Hose reel hose is provided but not functional and all hose reel nozzles found missing.
- 4 Terrace level fire fighting pump capacity of 450lpm is provided but not functional.
- Exit signage is not provided at strategic locations in the school building.
- 6 Standby power supply is not provided.
- Electrical panel below staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of new school building is at your own risk & responsibility.

Yours f

Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, 16, Rajpura Road, Delhi.