



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 359

Dated: 07/05/2025

To

The Principal
M.C. Primary Girls/Boys School,
C-Block, Jahangir Puri, Delhi-110033.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Girls/Boys School (I.D No-1253002/03) at C-Block, Jahangir Puri, Delhi-110033.

Sir,

Please refer to your letter no. Nil dated 08/04/2025 and received in this department vide outdoor dairy no.381 dated 08/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/04/2025 to verify the fire safety measures issued vide NBC Part-IV and observed that the building was comprised of ground & first floor only. At the time of inspection Sh. Vikram Singh (Incharge) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Nos. of continues staircase is provided only one from ground to terrace level against the requirement of both staircase continues from ground to terrace level.
- 2 The school room doors size is provided 01m against the requirement of 1.20m.
- 3 Hose reel hose is not provided.
- 4 Terrace level fire fighting pump capacity of 450lpm is not provided.
- 5 Terrace level fire water tank capacity of 10,000ltrs is not provided.
- 6 Exit signage is not provided at strategic locations in the school building.
- 7 Electrical panel below in staircase needs to be removed/shifted in a safer place.
- 8 As built plan of the school duly signed by registered architect & management shall also be submitted.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, 16, Rajpura Road, Delhi.