



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 353

Dated: 07/05/2025

To

The Principal  
M.C.Primary Girls/Boys School,  
A-Block, 25 Foot Road, Near Peeli Kothi,  
Nathupura-I, Delhi-110084.

**Sub:** Regarding issuance of fire safety certificate in r/o M.C. Primary Girls/Boys School (School ID No- 1253023/24) located at A-Block, 25 Foot Road, Near Peeli Kothi, Nathupura, Delhi-110084.

Sir,

Please refer to your letter no. nil dated 09/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors. At the time of inspection Mr. Maheshwar Rai (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The approach road width is provided 04m against the requirement of 06m for movement of fire engine in case of emergency fires.
2. Fire extinguishers provided but found not functional.
3. Hose reel hose provided but not functional.
4. Terrace level fire pumps capacity 450lpm provided but not functional.
5. Overhead fire water tank capacity 10,000ltr provided but empty.
6. Exit signage's not provided at strategic location in the school building.
7. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.