

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 335

Dated: 05/05/2025

To,

The Principal,
M.C. Primary Girls School,
Haiderpur, Delhi-110088.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary Girls School located at Haiderpur, Delhi- 110088.

Sir,

This has reference to your letter no. nil received through outdoor diary no. 330 dated 08.04.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 24.04.2025 to see the to see the compliance of shortcomings issued vide this department letter no. F6/DFS/MSWZ/2019/6992 dated 20/11/2019. Smt. Seema Rani (In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. First aid hose reels found not provided.
2. Terrace level pump found not provided.
3. Overhead tank of 10,000 ltrs capacity exclusively for fire fighting pump found not provided.
4. Electrical meter and panel installed under the staircase has to be removed to a safer place or been segregated.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.