



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 361

Dated: 07/05/2025

To

The Incharge,
M.C. Primary Girls/Boys School,
Village Sarai Pipal Thala, Near
Azadpur Mandi, Delhi-110033

Sub: - Regarding grant of fire safety certificate in r/o M.C. Primary Girls/Boys School (School I.D No- 1253053/54) Village Sarai Pipal Thala, Near Azadpur Mandi, Delhi-110033

Sir,

Please refer to your letter no- nil received in this department vide outdoor dairy no- 756 dated 17/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 26/04/2025 in the presence of Sh. Vinod Kumar (Incharge) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school premises is comprised of ground & first floor only. The observations/ shortcomings made are as under:-

1. The approach road is not accessible for movement of fire engine in case of emergency fires.
2. The school class room doors size is provided 94cm against the requirement of 01m.
3. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, Rajpura Road, Delhi.