

C-14 DFA+FT

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/NDZ/2025/289

Dated: 25/04/2025

To

The principal,  
M.C. Primary School,  
Bhagirathi Vihar, Shahdara North East  
Delhi-110094.

**Sub: Regarding Fire Safety Certificate in r/o M.C. Primary School, Bhagirathi Vihar, Shahdara North East, Delhi-110094.**

Sir,

This has reference to your email dated 22/04/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 22/04/2025 in the presence of Mr. Mohit Sharma to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present school is Ground Floor, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor only. Fire safety measures were checked as per the rules and following shortcomings were observed.

1. Hose reel hose provided but found non-functional.
2. Fire Pump of capacity 450LPM provided on terrace but found non-functional.
3. Overhead tank capacity of 10,000ltr found removed.
4. Exit signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub-Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/Fire/Home\\_Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home_Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/Fire/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Forms)

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, Udyog Sadan, Plot No. 419, FIE, Patparganj Industrial Area, Delhi-110092.