



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 350

Dated: 07/05/2025

To

The Principal
M. C. Primary School Boy
at Wazirabad Water Works-II, Delhi-54.

Sub: -Regarding issuance of fire safety certificate in r/o M. C. Primary School Boy (ID NO-1253089) at Wazirabad Water Works-II, Delhi-110054.

Sir,

Please refer to your letter No- Nil dated: 14/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors. At the time of inspection Sh. Sanjay Kr. Sinha was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional and nozzle found missing.
2. Terrace level fire pump capacity of 450lpm is provided but not functional.
3. Exit signage is not provided at strategic locations in the school premises.
4. Electrical panel below staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Gang)
Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, Rajpura Road, Delhi.