



d/23

75  
आज़ादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2025/ 328

Dated: 05/05/2025

To,

The Principal,  
M.C. Primary School,  
Karampua G- Block,  
New Delhi - 110015.

Sub : Regarding issuance of Fire safety Certificate in respect of M/s. M.C. Primary School, G- Block, karampura, New Delhi - 110015.

Sir,

Please refer to your letter no. Nil dated 20/03/2025, received through outdoor diary No. - 14834 dated 21/03/2025, on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 17/04/2025 in the presence of Smt. Santosh (Incharge) and observed that this department has already issued a letter to rectify the shortcomings vide letter No. F6/DFS/MS/School/WZ/2022/606 dated 23/09/2022, F6/DFS/MS/School/WZ/2023/387 dated 11/09/2023 & F6/DFS/MS/School/WZ/2024/270 dated 21/05/2024 is still not complied.

In view of above Shortcomings the application for Issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Gang)  
Director

Copy to:

1. The Directorate, Directorate of Education MCD, Civic Centre, Delhi.

02/5/2025



c/20

75  
आज़ादी का  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 270

Dated: 21/05/2024

To,

The Principal,  
M.C. Primary School,  
Karampua G- Block,  
New Delhi - 110015.

Sub : **Regarding renewal of Fire safety Certificate in respect of M/s. M.C. Primary School, G- Block, karampura, New Delhi – 110015.**

Sir,

Please refer to your letter no. Nil dated 24/04/2024 received through outdoor diary No. - 985 dated 24/04/2024 on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 13/05/2024 in the presence of Smt. Santosh (HOS) and observed that this department has already issued a letter to rectify the shortcomings vide letter No. F6/DFS/MS/School/WZ/2022/606 dated 23/09/2022 & F6/DFS/MS/School/WZ/2023/387 dated 11/09/2023 is still not complied.

In view of above Shortcomings the application for Issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.


Yours Faithfully

  
(Atul Garg)  
Director

Copy to:

1. Directorate of Education, Old secretariat, Delhi – 110054.

  
13/5

  
14/5/2024





**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/ 387

Dated: 11/09/2023

To

The Principal,  
M.C Primary School,  
Karampura G-Block,  
New Delhi -110015.

**Subject: Regarding issuance of Fire safety Certificate in respect of M/s. M.C. Primary School, G- Block, New Delhi – 110015.**

Sir,

Please refer to your letter dated 28/07/2023 received through outdoor diary no. 4761 dated 10/08/2023 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned of this department on 25/08/2023 in presence of Smt. Roopvati (Principal) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/606 dated 23/09/2022.

However, the Status of the Shortcomings is as under.

S. no.	Shortcomings	Status
1.	First-Aid Hose Reels at each floor are provided but not functional.	Not Rectified
2.	Terrace fire pump of capacity 450 LPM capacity on terrace is provided but not functional.	Not Rectified

In view of above shortcomings the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Atul Garg)  
Director

Copy To: -

1. The Directorate of Education, Old Secretariat, New Delhi.

1/2 84  
31/8/2023



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 606

Dated: 23/8/22

To

The Principal,  
North Delhi Primary Model School,  
Karampura G-Block,  
New Delhi -110015.

**Subject: Regarding issuance of Fire safety Certificate in respect of M/s. North Delhi  
Primary Model School, G- Block, New Delhi – 110015.**

Sir,

Please refer to your letter dated 30/07/2022 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned on 02/09/2022 in the presence of Smt. Roopvati (Principal), during inspection it has been observed that the building is comprised of Ground + 03 Upper Floors. Fire Safety arrangements such as Fire Extinguisher, First-Aid Hose reel, Exit signages, Over Head Tank, etc are provided. However, the following shortcomings were observed:-

1. First-Aid Hose Reels at each floor are provided but not functional.
2. Terrace fire pump of capacity 450 LPM capacity on terrace is provided but not functional.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is cannot consider at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy To: -

1. The directorate of Education, old secretariat, Delhi.

ok  
21/9/22