

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 354

Dated: 07/05/2025

To

The Principal M.C. Primary Co-ed School, Kabir Basti, Malka Ganj, Delhi-110007.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Co-ed School (I.D No-1253079) at Kabir Basti, Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter no. Nil dated 16/04/2025 and received in this department vide outdoor dairy no.780 dated 21/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/04/2025 to verify the fire safety measures issued vide NBC Part-IV and observed that the building was comprised of ground & first floor only. At the time of inspection Smt. Vaishali (Incharge) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 There is 02 nos. of staircases is provided width of 1.70m & 1.25m (iron) against the requirements of 1.50m each and alternate staircase is not continuous from ground to terrace level.
- 2 The class room doors size is provided 90cm against the requirements of 1.20m.
- 3 Hose reel hose is not provided.
- 4 Terrace level fire fighting pump capacity of 450lpm is not provided.
- 5 Terrace level fire water tank capacity of 10,000ltrs is not provided.
- 6 Exit signage is not provided at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

Director 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, Rajpura Road, Delhi.