



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE; NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 685

Dated: 18/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary School** located at **Main Road Burari (Boys), Delhi-110084** comprised of **Ground & first floor only** owned/ occupied by the **M.C. Primary School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **04.07.2024** in the presence of **Sh. Ramesh Kumar (Incharge)** and that the building/premises is fit for occupancy "**Group B Educational**" with effect from **18/07/2024** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **18/07/2024** at New Delhi

(Atul Garg)
Director
Ph: 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Incharge, M.C. Primary School located at Main Road Burari (Boys), Delhi-110084

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

17/4

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School at Main Road Burari (Boys), Delhi-110084.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Composition of building : Ground & first floor only
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 04.07.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Ramesh Kumar (Incharge)
10. Year of Construction : 2017
11. Applicant's letter No. : Latter No-Nil Dated: 04.06.2024 & DFS Dairy No-2531 dated 05.06.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50M	1.50m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Required	1.20m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
	Fire Extinguishers.			
	• Total numbers	04os	04nos	MR
	• Types	ABC/Co2	ABC-04	MR

		N/S	ISI Marked	Yes	MR
	• ISI marking				
6	First-Aid Hose Reels.				
	• Total numbers on each floor	NA	NA	NA	
	• Length of hose reel hose	NA	NA	NA	
	• Nozzle diameter	NA	NA	NA	
7	Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8	MOEFA	NA	NA	NA	
9	Public Address System.	NA	NA	NA	
10	Automatic Sprinkler System.				
	• Basement	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11	Internal Hydrants				
	• Size of riser/down-comer	NA	NA	NA	
	• Number of hydrants per floor	NA	NA	NA	
	• Hose Box	NA	NA	NA	
12	Yard Hydrants.				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13	Pumping Arrangements.				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A	N/A	
	➤ Head of Main pump	N/A	N/A	N/A	
	➤ Number of main pumps	N/A	N/A	N/A	
	➤ Jockey Pump out put	N/A	N/A	N/A	
	➤ Jockey pump head	N/A	N/A	N/A	
	➤ Standby Pump out put	N/A	N/A	N/A	
	➤ Standby Pump Head	N/A	N/A	N/A	
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A	
	➤ Pump House Access	N/A	N/A	N/A	
	• Terrace level				
	➤ Discharge of pump				
	➤ Head of the pump	NA	N/A	NA	
	➤ Power Supply	NA	N/A	NA	
	➤ Auto Starting of pump	N/A	N/A	N/A	
		N/A	N/A	N/A	
14	Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA	

4/6

MR

NA

NA

/A

	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	N/A	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/School/2014/2942 dated 26.12.2014

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to grant Fire Safety Certificate.

DO (NW)

10/07/2024

24 CFO (NW)

CFO

Director

11/3

11/3

11/3

Signature of the Inspecting Officer

Name:- C.L. Meena

Designation:- Asst. Div. Officer (RN)

DCFO/.....
Dated.....11/7/2024

P.T.O.