

c/13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2025/ 389  
To

Dated: 14/05 /2025

The Principal,  
M. C. Primary Girls Pratibha School,  
New Kucha Chalan,  
Darya Ganj, Delhi.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M. C. Primary Girls Pratibha School, New Kucha Chalan, Darya Ganj, Delhi.**

Sir,

This has reference to letter outdoor diary no. 476 dated 11.04.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 06.05.2025 in the presence of Mr. Tejpal (Attendant) and observed that the building is comprised of ground + 02 upper floors. During the inspection, following shortcomings were observed

1. Hose reel on each floor not provided.
2. Terrace tank capacity 10,000 ltrs. for fire fighting not provided.
3. Terrance fire fighting pump capacity 450 LPM not provided.
4. Exit signages are not provided.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.