

e 24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

Dated:..16/05/2025

No.F6/DFS/MS/2025/ School/ 662

**FIRE SAFETY CERTIFICATE**

Certified that the M.C. Primary School, Rameshwari, Nehru Nagar, Karol Bagh, New Delhi comprises of **Ground floor only** owned/occupied by MCD, was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/2019/SZ/1016 dated 14/05/2019. Now, the premises was re-inspected by the officer concerned of this department on 07/05/25 in the presence of Sh. Santosh Sharma ( Principal) and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Sub-Div. B-I Group B "Educational Building"** with effect from ..16/05/2025 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on .....16/05/2025..... at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD Civic center New Delhi.
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, M.C. Primary School, Rameshwari, Nehru Nagar, Karol Bagh, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

# INSPECTION REPORT

1. Name & address of the building:- M.C. Primary School, Rameshwari, Nehru Nagar, Karol Bagh, New Delhi.  
 2. Type of occupancy:- Educational Group B-I, Ground Floor Only  
 3. Type of case:- Renewal  
 4. Details of previous FSC:- No.F6/DFS/MS/School/2019/SZ/1016 dated 14/05/2019.  
 5. Fire safety directives No.- N/A  
 6. Date of inspection:- 07/05/25.  
 7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)  
 8. Name & designation of officer From the building side:- Sh. Santosh Sharma ( Principal)  
 9. Year of construction:- 1957  
 10. Applicant's letter No:- letter no. nil dated 21/03/25.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	DOE Cir. Dated 01.03.2011/	Provided at site	Old Case	Remarks
1.	Access to Building				MR/NMR
	1) Road width	Accessible	05 mtrs.		MR, old case
	2) Gate width	--	190 cms.		MR, old case
	3) Width of internal road	NA	NA		NA
2.	Number, Width Type & Arrangement of Exits				
	A. Number of staircases				
	1. Upper floors	N/A	N/A		N/A
	2. Basements	N/A	N/A		N/A
	B. Width of staircase				N/A
	1. Upper floors	N/A	N/A		N/A
	2. Basements	N/A	N/A		N/A
	C. Protection of exits				N/A
	1. Fire check door	N/A	N/A		N/A
	2. Pressurization	N/A	N/A		N/A
	D. No. of continuous staircase to terrace	N/A	N/A		N/A
	E. Width of corridor	N/A	N/A		N/A
	F. Door size	1 mtr.	83x 205 cms		N/A
3.	Compartmentation				MR, old case
	1) Fire check door	N/A	N/A		N/A
	2) Sealing of electrical shafts	N/A	N/A		N/A
	3) Fire rating of shaft door	N/A	N/A		N/A
	4) Water curtain	N/A	N/A		N/A
	5) Fire Dampers	N/A	N/A		N/A
4.	Smoke Management System				N/A
	1) Basements	N/A	N/A		N/A
	2) Upper floors	N/A	N/A		N/A
5.	Fire Extinguishers				N/A
	1) Total numbers	02 Nos.	Provided		MR
	2) Types	ABC & CO2	Provided		MR
	3) ISI marking	ISI marking	Provided		MR
6.	First-Aid Hose Reel				
	1) Total number of each floor	N/A	N/A		N/A



N/20

	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A

15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: 02 fire bucket			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Director Education Circular, the FSC issued vide letter No.F6/DFS/MS/School/2019/SZ/1016 dated 14/05/2019, if agreed, we may renew the FSC under Rule 35(6) of the Delhi Fire Service rules 2010, According , DFA is put up for kind perusal and approval / signature please .

Signature of the Inspecting Officer



Name: - Ravinder Singh  
Designation: - ADO (CC)

*DAC*

*9/5/25*

*10/5/2025*  
*Director*  
*17/5/25*

*As approved for put up for kind perusal and signature please*