

c/o

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/ 422

Dated: 21/05/2025

To

The Principal,
M.C. Primary School,
Sadar Bazar, Delhi - 110006.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M. C. Primary School, Sadar Bazar, Delhi - 110006.

Sir,

This has reference to your letter outdoor diary No. 229 dated 04.04.2025 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 15.05.2025 in the presence of Mr. Anil Kumar (Sweeper) and found that the school building is comprised of ground plus one upper floor have complied the shortcomings issued vide letter no. F6/DFS/MS/School/2014/1671 dated 22.07.2014 except following which still exists.

1. An additional fire escape staircase not less than 0.75 m wide is required.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,


(Anil Garg)
Director
Delhi Fire Service
Tel: 011-23414000
o/c
10/05/25
765

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.