



C-33

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No. F6/DFS/MS/School/2025/SZ/617

Dated: 07/05/2025

FIRE SAFETY CERTIFICATE

Certified that the building of M.C. Primary School (Boys) at Samalka. New Delhi-110037 (School ID: 1757239), comprised of 02 interconnected blocks. Ground + One upper floor only, owned/occupied by MCD, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2022/SZ/582 dated 27/05/2022. The premise was re-inspected by the officer concerned of this department on 25/04/2025 in the presence of Ms. Anita Rani (Principal) and observed that the fire prevention and fire safety arrangements provided in the premises are in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Circular No. 3298-3398 dated 01/03/2011 issued by the Director of Education, Govt. of NCT of Delhi and that the building/ premises is fit for occupancy class B "Educational" with effect from 07/05/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
Ph. 011-23414000

Copy to: -

1. The Director of Education, Municipal Corporation of Delhi, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002
2. The Principal, M.C. Primary School (Boys) Samalka. New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

- 1) All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 2) All the staff should know the correct method of operation of portable fire safety equipments.
- 3) Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 4) The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 5) The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
- 6) The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	M.C. Primary School Samalka (Boys), New Delhi-110037 (School ID: 1757239)		
2.	Building comprised of	02 interconnected blks of Ground + 01 UFs.		
3.	Type of occupancy	Educational		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/School/2022/SZ/582 Dt. 27/05/2022		
6.	Fire Safety directives letter No.	DOE Circular No. 3298 to 3398 dated 01/03/2011		
7.	Date of Inspection	25/04/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side.	Ms. Anita Rani (Principal)		
10.	Year of construction	2010		
11.	Applicant's letter No.	Outdoor diary No 14610 dated 18/03/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirement U/R 35(6)	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr	06 mtr	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	02 No's	03 No's	MR
	➤ Basements	N/A	N/A	N/A
	b. Width of staircases			
	➤ Upper floors	1.50 mtr	1.98m, 1.60m & 1.30m	MR
	➤ Basements	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers at each floor Types IS marking 	Required	10 No's	MR
		ABC & CO ₂	Provided	MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

JK

7.	Automatic fire detection and alarming system	N/A	N/A	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2022/SZ/582 dated 27/05/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

CHO (MS)

Director

Sir, F.T letter is put up for your sig. pr

Director

S Kumar
2/05/25