

213



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 138

Dated: 05/03/2025

To,

The Principal/Incharge,
Nigam prathmik Vidyalaya,
lalita Block Shastri Nagar,
New Delhi -110052.

Sub: Inspection report in r/o. M.C. Primary School, Located at lalita Block Shastri Nagar, New Delhi -110052.

Sir,

With reference to your Email dated 13/12/2024, on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 14/02/2025, in the presence of Sh. Satish Kumar (Incharge) to see the functioning of the fire safety arrangements/equipment's provided in the building.

During inspection, it has been observed that the said school building is comprised of Ground + 02 Upper Floor, was already issued FSC vide letter No. F6/DFS/MS/School/wz/2022/520 dated 13/05/2022, Fire Safety Arrangements such as, Fire Extinguishers, First Aid Hose Reels, Terrace pump, etc. are provided. However, following shortcomings were observed: -

1. First Aid Hose Reel is provided but not functional.
2. Terrace fire pump of 450lpm provided but not functional.
3. Exit signage's are not provided.

In view of above shortcomings, the application for renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang) / 27
Director

Copy To:-

1. The Directorate of Education Old Secretariat Delhi - 110054.

1/2 JLP
04/3/2025