

C/31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 322

Dated: 02/05/2025

To,
The Principal,
M.C. Primary School,
Tilak Nagar No. 4 II, New Delhi-110018.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M.C. Primary School at Tilak Nagar No. 4 II, New Delhi-110018.

Sir,

Please refer to your letter dated 17.01.22025, received through online email Id Rashmi.arora100@gmail.com, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 28.04.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Nirmla (In-charge) was present and it was observed that the school building comprised of ground plus two upper floors, and have following shortcomings: -

1. Hose reels/hydrant found provided but not functional.
2. Terrace fire pump of 450 LPM is provided but found not functional.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, MCD, Dr. S.P. Mukherjee Civic Centre, New Delhi- 110002.