

e31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2025/ 981

Dated: 11/08/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C Primary Co-ed School, located at J.J. No.02, Raghubir Nagar, New Delhi-110027.(School ID-1556073), comprised of ground + 01 upper floor only, Owned/occupied by M.C Primary Co-ed School, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/305 dated 23/03/2022. The premises was re - inspected by the officer concerned by this department on 04/07/2025, in the presence of Ms. Geeta Kohli (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with Circular No.F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by the Director of Education Govt. Of NCT of Delhi and the building/premises is fit for the occupancy class "Educational" Group B (ground + 01 upper floors only & except hall) with effect from 11/08/2025 for a period of three years and subject to compliance of the conditions. Condition mentioned below.

Issued on ...11/08/2025 at New Delhi.


Virendra Singh
Chief Fire Officer

Copy to:

1. The Director, Directorate of Education, Civic Centre, New Delhi.
2. The Principal, M.C Primary Co-ed School, located at J.J. No.02, Raghubir Nagar, New Delhi-110027.(School ID-1556073). Email ID-hos1556073@mcdwestzone.in.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	M.C Primary Co-ed School, located at J.J. No.02, Raghubir Nagar, New Delhi-110027.(School ID-1556073)		
2.	Type of Occupancy	Educational (Ground + 01 Upper Floors)		
3.	Type of Case	Renewal		
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/305 dated 23/03/2022.		
5.	Fire Safety directives letter No	DOE 3298-3398 dated 01/03/2011		
6.	Date of inspection	04/07/2025		
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)		
8.	Name and designation of officers from the building side	Ms. Geeta Kohli (Principal)		
9.	Year of Construction	2018 (As per previous Inspection Report dated 08/03/2022)		
10.	Applicant's letter No.	Email dated 30/06/2025		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m Accessible NA	Provided 5 m Provided NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 NA	02 Provided NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 m NA	2 x 1.45 m Provided NA	MR old case NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.5 m	2 m provided	MR
	f. Door Size	1 m	2 x 1.20 m Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos. CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

Standby power supply		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/305 dated 23/03/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Handwritten: 10/7/2025

Handwritten signature: 10/7/2025

Handwritten signature: 10/7/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

Handwritten: 10/7/2025

Handwritten signature: 14/7/2025

Handwritten signature: 14/7/2025
Director

Handwritten signature: 10/7/2025

Sir, F.T is put up for your kind personal & signature please.

Handwritten signature: 10/7/2025
Pr. Director

Handwritten signature: 21/7/2025

Handwritten signature: 22/7/2025

Handwritten signature: 22/7/2025