



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 417

Dated:- 20/05/2025

To,

The Principal,
M. C. Primary School,
Sawan Park, C-Block, Ashok Vihar,
New Delhi-110052.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of M. C. Primary School, located at Sawan Park, C-Block, Ashok Vihar, New Delhi-110052

Sir,

Please refer to your email dated 28/02/2025, on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 15/05/2025 in the presence of Ms. Ruchika Atri (Teacher). However, the following shortcoming has been observed:-

1. First – aid hose reels found non-functional.
2. Terrace pump of 450 lpm found non-functional.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Anul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

16/05/25