

C 23



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F.6/DFS/MS/2025/School/WZ/1359

Dated: 27/11/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary Co-ed School Located at Bharat Nagar, New Delhi-110052 (School Id-1354138), comprised of Ground + 01 upper floor owned/occupied by M.C. Primary Co-ed School was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2022/1016 dated 15/09/2022. The premises was re-inspected by the officer concerned of this department on 17/11/2025 in the presence of Smt. Sangeeta Gulati (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from27/11/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on27/11/2025..... at New Delhi

(Signature)
 26/11/25

(S. K. Dua)

Dy. Chief Fire Officer (WZ)
 Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, M.C. Primary Co-ed School Located at Bharat Nagar, New Delhi-110052. (School Id-1354138),

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M.C. Primary Co-ed school Located at Bharat Nagar, New Delhi-110052.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Ground+01 upper floor)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2022/1016 dated 15/09/2022.			
5. Fire Safety directives letter No	DOE 3298-3398 dared 01/03/2011			
6. Date of inspection	17.11.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)			
8. Name and designation of officers From the building side	Smt. Sangeeta Gulati (Principal)			
9. Year of Construction	2018			
10. Applicant's letter No.	Online e-mail dated 25.10.2025			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5mts	1.50m & 1.24m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01nos.	Provided	MR
	e. Width of Corridor	1.5 m	2.10m	MR
	f. Door Size	1 mts	1.12m	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	a) Total numbers	05nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	NA	NA	NA
	b) Length of hose reel hose	NA	NA	NA
	c) Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			

	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	NA	NA	NA
	b) Number of hydrants per floor	NA	NA	NA
	c) Hose Box	NA	NA	NA
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

a) Total Area	NA	NA	NA
b) Location	NA	NA	NA
19. Fire Control Room			
a) Detector System Panel	NA	NA	NA
b) Flow Switch Panel	NA	NA	NA
c) PA System Panel	NA	NA	NA
d) Battery backup	NA	NA	NA
e) Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2022/1016** dated **15/09/2022** is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Ajay
18/11/25
Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Wazirpur/MN)**

DO(W)

11/11/11

Dy. C/O (WZ)

19/11/25

Principal Director

Dy. C/O to Secy.

Dy. C/O (WZ)

F.T. please.

18/11/25

ADO (WZ)

FT letter to put up for end para
and signature para.

18/11/25

Dy. C/O (WZ)

18/11/25

F.P. wing