



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C/28

No. F6/DFS/MS/2025/School/ 220

Dated: 15 / 04 / 2025

To,

The Principal
M.C. Primary School,
Bhalswa Dairy-II, Delhi-42

Sub:- Regarding issuance of fire safety certificate in r/o M.C. Primary Girls/Boys School located at Bhalswa Dairy-II, Delhi -110042.


Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no.14580 dated: 17.03.2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.03.2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 blocks, one old block comprised of ground + first floor & one new block comprised of ground + 02 upper floors only. At the time of inspection Sh. Sanjeev (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher found removed in the school building.
2. Hose reel hose not provided.
3. Pump capacity of 450 LPM with 40mtr head not provided.
4. Overhead fire water tank capacity of 10,000ltr provided but damaged/leakage condition.
5. Exit signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully



(Virender Singh)
Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, Delhi.