



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 385

Dated: 13 / 05 / 2025

To

The Principal,
M.C. Pratibha School (Girls)
Bijwasan, New Delhi-110061

Sub: **Regarding Fire Safety Certificate in r/o M.C. Prathibha School (Girls), Bijwasan, New Delhi-110061.**

Madam,

Please refer to the email dated 08/03/2025 received from Id. mcpsgirlsbijwasan@gmail.com on the subject above. In this connection, it is to inform you that the school premise was inspected by the officer concerned of this department on 29/04/2025 in your presence from fire safety point of view. During the course of inspection, the shortcomings observed are as below: -

1. Hose reel found non-functional.
2. Terrace pump found non-functional.
3. Overhead water storage tank of 10,000 ltr for firefighting found removed.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Municipal Corporation of Delhi, 9th Floor, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002.