

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 1051

Dated: 22/08 /2025

## FIRE SAFETY CERTIFICATE

Certified that M.C Primary Co-ed School (School ID No-1253007) located at J-Block, Jahangir Puri, Delhi-110033 comprised of Ground & first floor only owned/occupied by M.C Primary Co-ed School was issued FSC by this department vide letter no. F6/DFS/MS/2022/School/1316 dated: 14/12/2022. The premises was inspected by the officer concerned of this department on 05/08/2025 in presence of Sh. Sushil Kumar (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ... 22/08/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ... 22. 08. 2.25... at New Delhi by

Virendra Singh Chief Fire Officer Delhi Fire Service

### Copy to: -

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.

2. The Principal, M.C. Primary Girls School located at J-Block, Jahangir Puri,, Delhi-110033.

# Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.

2. All the fire safety arrangements provided therein shall be maintained in good working condition

3. Any loss of life or property due to non-functional fire safety measures shall be at the

4. All the staff members must know the correct method of operation of firefighting system.

5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first Rules http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms. The form is

6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-

2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.

7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its

#### INSPECTION REPORT

1. Name & address of the building

: M.C Primary Girls School at J-Block, Jahangir Puri, Delhi-110033.

2. Type of Occupancy

: Educational

3. Composition of building

: Ground & first floor only

Type of Case

: Renewal

5. Details of previous NOC

: F6/DFS/MS/2022/School/1316 dated: 14/12/2022

6. Fire Safety directives letter No

: Nil

7. Date of inspection

: 05/08/2025

8. Name of the Inspecting Officers

: ADO (RN)

9. Name and designation of officers

from the building side

: Sh. Sushil Kumar (Principal)

10. Year of Construction

: 2012

11. Applicant's letter No.

: Letter No. Nil dated: 23/07/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D. O. E Circula 01.03.2011 requir		Provided at site	Remarks MR/NM			
	Access to building							
	Road width	Accessible Accessible		essible	MR			
	Gate width	Accessible	Ac	cessible	MR			
	Width of internal road	NA	737,7434	NA	NA			
	Number, Width, Type & Arrangement of Exits		75					
	a. Number of staircases							
	Upper Floors	02	1	02	VO			
	Basements	NA NA		Section 1	MR			
	b. Width of staircases	NA NA		NA	NA			
	Upper Floors							
	Basements	1.5m	02 nos. (	of 1.5m each	MR			
	TO 255 STREET COM.	NA		NA	NA			
	c. Protection of exits			L				
	Fire check door	NA		NA	NA			
	Pressurization	NA		NA	NA			
	d. No. of continuous staircases to terrace	01		01	MR			
	e. Width of Corridor	NA		NA .	NA			
	f. Door Size	01m		olm .	23925			
3	Compartmentation.			71111	MR			
	Fire check door	NIA						
	Sealing of electrical shafts	NA		NA	NA			
	Fire Rating of shaft door	NA NA		NA	NA			
	Water Curtain	NA NA	_	NA NA	NA			
	Fire Dampers	NA NA		NA NA	NA			
4	Smoke Management System.							
	Basements	NA		NA I	NA			
	Upper floors	Required	Natural	Ventilation	MR			
5	Fire Extinguishers							
	Total numbers	04nos	0.	5nos	MR			
	<ul> <li>Types</li> </ul>	ABC/Co2	AB	C-05	MR			
	ISI marking	ISI Marked	1	Yes	MR			
6	First-Aid Hose Reels.							
	Total numbers on each floor	NA	1	NA	NA			
1	<ul> <li>Length of hose reel hose</li> </ul>	NA	1	NA .	NA			
1	Nozzle diameter			189(5)	5355AR			

		MIR					
Au	utomatic fire detection and alarming system.						
	Type of detectors	NA	NA				
	Location of Main Panel	NA	A COPEN	N.A			
	Location of Repeater Panel	NA	NA	NA			
	Alternate source of power	NA	NA	NA			
-	Hooters' Location	NA	NA	NA			
1000	OEFA	NA	NA NA	NA NA			
	ublic Address System.	NA	NA NA	NA NA			
A	Automatic Sprinkler System.						
	Basement	NA	N/4				
	Upper Floor	NA	NA	NA			
3	Sprinkler above false ceiling		NA	NA			
7-	Asses I Hadrone	NA	NA	NA			
111	Internal Hydrants						
	Size of riser/down-comer	NA	NA	- N			
	Number of hydrants per floor	NA	NA NA	NA			
	Hose Box	NA	NA NA	NA			
Y	ard Hydrants.		NA	NA			
	Total number of hydrants	NA	NA	T			
	Hose Box	NA		NA			
		NA	NA	NA			
P	umping Arrangements.						
	Ground Level						
	Discharge of main Pump	N/A	N/A	27/4			
	➤ Head of Main pump	N/A	N/A	N/A N/A			
	Number of main pumps	N/A	N/A	N/A N/A			
	<ul><li>Jockey Pump out put</li><li>Jockey pump head</li></ul>	N/A	N/A	N/A			
	Standby Pump out put	N/A	N/A	N/A			
	➤ Standby Pump Head	N/A	N/A	N/A			
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A			
	> Pump House Access	N/A	N/A	N/A			
	<ul> <li>Terrace level</li> <li>Discharge of pump</li> </ul>	NA	N/A	NA NA			
	> Head of the pump	NA	N/A	NA NA			
	➤ Power Supply	N/A	N/A	N/A			
-	➤ Auto Starting of pump	N/A	N/A	N/A			
(	Captive Water Storage for fire fighting.						
	Underground tank capacity	NA NA	NA	NA			
	> Draw-off connection	NA	NA	NA			
	> Fire service inlet	NA	NA	NA			
	Access to tank	NA	NA	NA NA			
1	Overhead Tank capacity	NA	N/A	NA NA			
	Exit Signage.	NA	NA	INA			
	Provision of Lifts.	27/4	N/A	N/A			
	Pressurization of Lift Shaft	N/A N/A	N/A N/A	N/A			
	Pressurization of Lift lobby	N/A N/A	N/A	N/A			
	Communication In lift Car  Communication Spring Spring	N/A	N/A	N/A			
	Fireman's Grounding Switch  Life Signers	N/A -	N/A	N/A			
0	Lift Signage  Standby power supply	N/A	N/A	N/A			
	WOODS-19-1-78-1-78-1-78-1-78-1-78-1-78-1-78-1	. /		N/A			
	Refuge Area.  > Total Area	N/A	N/A	THIO CASALS			
-	<ul><li>Total Area</li><li>Location</li></ul>	N/A	N/A	N/A			

19	Fire Control Room			
	Detector System Panel	N/A	N/A	N/A
	Flow Switch Panel	N/A	N/A	N/A
	PA System Panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20 -	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A.	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended for department letter of even no. this vide certificate issued renewal of fire safety F6/DFS/MS/2022/School/1316 dated: 14/12/2022.

> Signature of the Inspecting Name: - C.L. Meena

Designation: - ADO/RN

D.B. Mukharjee (DO/NW) 07/08/2020