

c/14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/NDZ/School/2025/ 530

Dated: 18 / 06 / 2025

To

The Principal,
M C Primary School,
Kucha Chelan (Co-Ed),
Darya Ganj, New Delhi - 110002.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o M C Primary School, Kucha Chelan (Co-Ed), Darya Ganj, New Delhi - 110002.

Sir,

This has reference to letter outdoor diary No. 2171 dated 28.05.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 11.06.2025 in the presence of Mohd. Hamid (Attendant) and observed that the school building is comprised of ground plus one upper floor. During the inspection, following shortcoming was observed:-

1. The school building is not accessible to fire engine as approach road width is less than 06 mtrs.
2. Fire extinguishers provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.