## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 557

Dated: 01/07/2025

To,

The Principal, M.C. Primary Co-ed School, Hiranki, Delhi-110036.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary Co-ed School located at Hiranki, Delhi- 110036.

Sir,

This has reference to your application in Form 'I' received through outdoor diary no. 793 dated 21.04.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 25.06.2025 to see the to see the compliance of the requisite fire safety measures. Sh. Jagvir Singh Rana (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. The road width found 3.5 m against the required width of 6 m.

2. There is only one staircase reaches up to terrace against the requirement of both the staircases reaches up to terrace.

3. First aid hose reels found not provided.

4. Terrace level pump of 450 lpm discharge capacity found not provided.

5. Overhead tank of 10,000 ltrs capacity found not provided.

6. Exit signage's are not provided.

7. Electrical panel and electric meter installed under the staircase have to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

Atur Garg Director

7. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.