

0117

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/school/2025/ 308

Dated: 01.05.2025

To,

Mrs. Shashi Bala ( Incharge),  
M.C Primary School,  
Jhandewalan, Ward no. 92 (KBZ),  
New Delhi.

**Sub:** Application for issuance of fire safety certificate in respect of M.C Primary School,  
Jhandewalan, Ward no. 92 (KBZ), New Delhi.

Sir,

This has reference to letter no. nil dated 20/03/25 & DFS diary no. 14742 dated 20.03.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on dated 21/04/25 in presence of Incharge and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/GH/NDZ/2023/399 dated 12/09/2023 (copy enclosed) has not been complied so far.

In view of above, FSC can't be issued till the compliance of the shortcomings issued vide aforesaid letter.

Encl: As above.

Yours faithfully,

(Atul Garg)  
DIRECTOR

Delhi Fire Service

**Copy to :**

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi -54.

C/116

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2023/ 399

Dated:-12/09/2023

To,  
The Incharge,  
M/S M.C. Primary School,  
Jhandewalan Ward No. 92(KBZ),  
New Delhi -1100055.

**Sub: Regarding issuance of FSC in r/o M.C. Primary School, Jhandewalan Ward No. 92(KBZ), New Delhi -1100055.**

Sir,

This has reference to your letter no. **nil** dated 11.08.2023, on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 31.08.2023 in the presence of **Incharge** and following shortcomings were observed.

1. Hose reel found non functional.
2. The pump found non functional.
3. Overhead fire water tank of 10,000 liter capacity is not provided.
4. Exit Signage not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,

(Atul Garg)

**DIRECTOR**

Delhi Fire Service

**Copy to:-**

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.