

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C-54

No. F6/DFS/MS/School/WZ/2025/153

Dated: 14/02/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C. Co-ed Primary School, Located at Madipur Village, New Delhi - 110063. (School ID-1556083), comprised of ground + 01 upper floors, owned/Occupied by M.C. Co-ed Primary School, was issued FSC vide letter No F6/DFS/MS/School/MN/2022/182 dated 17/02/2022. The premises was re - inspected by the officer concerned by this department on 07/02/2025, in the presence of Smt. Asha Hans (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with the DOE Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and found that the building / premises is fit for the occupancy class "Educational" Group B with effect from 14/02/2025 for a period of three years in accordance subject to the conditions mentioned below.

Issued on 14/02/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, M.C. Co-ed Primary School, Located at Madipur Village, New Delhi - 1100636.(School ID-1556083), Email ID:-mcpsmadipur1@gmail.com.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | |
|-----|---|---|
| 1. | Name & address of the building | M.C. Co-ed Primary School, Located at Madipur Village, New Delhi - 110063 (School ID-1556083) |
| 2. | Type of Occupancy | Educational (Ground and one upper floor) |
| 3. | Type of Case | Renewal |
| 4. | Details of previous NOC | F6/DFS/MS/School/MN/2022/182 dated 17/02/2022 |
| 5. | Fire Safety directives letter No | Nil |
| 6. | Date of inspection | 07/02/2025 |
| 7. | Name of the Inspecting Officers | Sarabjeet Singh ADO (MN) |
| 8. | Name and designation of officers from the building side | Smt. Asha Hans (Principal) |
| 9. | Year of Construction | 2014 (As per previous Inspection Report) |
| 10. | Applicant's letter No. | Email dated 21/01/2025 |

The said school building comprised of Ground + 01 Upper Floor, was issued FSC vide letter no. F6/DFS/MS/School/MN/2022/182 dated 17/02/2022.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | As per Rule 35 (6) DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|--------|---|-----------------------------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 6m | Provided | MR |
| | • Gate width | 4.5 m | Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 03 Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50 m each | Provided | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | NA | NA |
| | e. Width of Corridor | 1.5 m | Provided | MR |
| | f. Door Size | 1m (class Rooms) 1.50m For (Hall) | Provided | MR (Old Case) |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 08 nos. | Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |

| | | | | |
|----|--|----|----|----|
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | | | |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | NA | NA | NA |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/ Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | NA | NA | NA |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage. | | | |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| Fire Control Room | | | | |
|-------------------|--|----|----|----|
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/MN/2022/182 dated 17/02/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

ADD/MN
02/10/25

24/01/25

10/2/25

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

10/2/25

01 NW
10/2/25

CFO
11/2/25
Director

Sir, F. T is put up for your kind personal & Signature please.

13/2/25

Director