



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ WZ/ 1357

Dated: 27/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M. C. Primary School, M-Block Co-ed at Mangolpuri, M-Block Delhi-110083 comprised of 02 Blocks, one block comprised of Ground Floor & one block comprised of Ground + First Floor Only owned/ occupied by M. C. Primary School, M-Block Co-ed was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/2022/School/WZ/331 dated 29/03/2022. The premises was inspected by the officer concerned of this department on 14/11/2025 in presence of Smt. Sunita Sharma (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from ..... 27/11/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 27/11/2025 at New Delhi by.

  
S.K. Dua

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, MCD, Zonal Office, First Floor, Sector-5, Rohini Zone, Delhi - 110085.
2. The Principal, M. C. Primary School, M-Block Co-ed at Mangolpuri, M-Block Delhi-110083.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".



**INSPECTION REPORT**

1. Name & address of the building : M. C. Primary School, M-Block Co-ed at Mangol Puri, Delhi-83.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 02 Blocks, Ground floor & Ground + first floor
5. Details of Previous NOC : F6/DFS/MS/2022/School/WZ/331 dated 29/03/2022 ✓
6. Fire Safety directives letter No : Director of Education Cir. dated 01/03/2011
7. Date of inspection : 14/11/2025
8. Name of Inspecting Officer : ADO (Rohini)
9. Name and designation of officers  
From the building side : Smt. Sunita Sharma (Principal)
10. Year of Construction : 1994 & 2004
11. Applicant's letter No. : Letter No. Nil dated 18/10/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.20m each	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	14nos.	15nos.	MR
	• Types	ABC/CO2	ABC-15	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

N/17

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
		NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	<b>Exit Signage.</b>			
		NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA



17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended for renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/331 dated 29/03/2022.

Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation ADO (Rohini)

DO (NW) 18-11-2025  
By CFO (WZ) on leave  
By CFO (MS2)  
18/11/25

Principal Director By. cfo to Beam.

By. CFO (MS2)

ADO/ Rohini

As approved, R.T. letter is put up for your signature please.

By CFO (WZ)

By 26/11/25

f.p. wing

22/11/2025