

C/16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2025/507

Dated: 09/06/2025

To,
The Principal,
M.C. Primary School,
Nai Basti, Kishan Ganj-II,
Delhi - 110007.

**Sub: Regarding issuance of fire FSC in r/o M.C. Primary School, Nai Basti,
Kishan Ganj-II, Delhi - 110007.**


Sir,

This has reference to your letter no. Nil dated nil & DFS diary no. 727 dated 17.04.2025, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 27/05/2025 in the presence of Mr. Pyarelal Meena (Incharge) and the following shortcomings were observed:-

1. Hose reel found non functional.
2. Fire pump 450 LPM non functional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


6/6/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.