



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

८-३५
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 1350

Dated:- 26/11/2025

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary Girls School, located at Nehru Vihar, Delhi-110054, building comprised of Ground + 01 Upper Floor, owned/occupied by M.C. Primary Girls School, has already been issued Fire Safety Certificate Vide Letter No. F6/DFS/MS/School/2022/1037 Dated 20/09/2022. The premises was re-inspected by the officer concerned of this department on 17/11/2025 in the presence of Ms. Alka Sachdeva (HOS) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and found that the school building is fit for Ground + 01 Upper Floors occupancy class "Educational Building" (Group B) with effect from 26/11/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 26/11/2025 at New Delhi by.


(S. K. DUA)
Dy. Chief Fire Officer (WZ)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, M.C. Primary Girls School, located at Nehru Vihar, Delhi-110054.

Conditions for validity of fire safety certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: M.C. Primary Girls School, located at Nehru Vihar, Delhi-110054
2. Type of Occupancy : Educational (G + 01 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2022/1037 dated 20/09/2022
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 17/11/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (BW/RN)
8. Name and designation of Officer
from the building side : Ms. Alka Sachdeva (HOS)
9. Year of Construction : 1985/2015
10. Applicant's letter No. : D/50/NVG/25-26 dated 22/09/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01/03/2011/ as per earlier FSC issued dated 20/09/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m 4.5 m NA	Provided 03 m NA	MR MR (old case) NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors Basements 	1.5 m each NA	1.5 m each NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 m	1.14 m	MR
3.	Compartmentation		NA	
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA 12 a/c per hour	NA Natural Ventilation	NA MR

5.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection. The shortcoming issued vide letter no. F6/DFS/MS/2025/School/735 dated 18/09/2025 found rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, **renewal of Fire Safety Certificate** issued vide letter no. F6/DFS/MS/School/2022/1037 dated 20/09/2022 **is recommended.**

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
18/11/25
Aman Kumar Lathar
ADO (BW/RN)

D.O. Wazir
Approval
18/11/25

Dy CFO/(CZ) on leave
Dy CFO/(CZ)
Xigmr
18/11/25

Principal Director

My. Cfo to [Signature]

My. Cfo (CZ)

F.T. please.

Xigp
20/11/25

ADO/BW

F.T. letter is put-up for your signature pl.

Dy CFO (CZ)

Xigp
24/11/25

Aman Kumar Lathar
20/11/25

F.P. wing