

c/17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2025/ 382

Dated: 13 /05/2025

To

The Principal,  
M.C. Primary School at Ram Nagar Bhawan,  
I & II, A.K. Road, Pahar Ganj, New Delhi.

**Sub: Regarding issuing of FSC in r/o M.C. Primary School at Ram Nagar Bhawan,  
I & II, A.K. Road, Pahar Ganj, New Delhi.**

Sir,

This has reference to your letter no. letter no. nil dated 03.04.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 02.05.2025 in the presence of Incharge and the following shortcomings were observed.

1. Hose reel found nonfunctional.
2. Terrace pump found nonfunctional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service  
MA 10/5/25

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.